



February 12, 2020

Ms. Sharmila Pradhan *CHMM*  
Environmental Safety Manager  
Montgomery College  
Office of Facilities  
9221 Corporate Boulevard  
Rockville, MD 20850

via e-mail: [sharmila.pradhan@montgomerycollege.edu](mailto:sharmila.pradhan@montgomerycollege.edu)

**RE: Indoor Environmental Quality and Mold Assessment Survey Report  
Counseling & Advising (CB) Building  
Montgomery College - Rockville Campus  
51 Mannakee Street, Rockville, Maryland 20850  
Tidewater Project Number: 5089-017**

Dear Ms. Pradhan:

Tidewater, Inc. (Tidewater) performed a pre-occupancy Indoor Environmental Quality (IEQ) and Mold Assessment survey within the Counselling & Advising (CB) Building of Montgomery College's Rockville, Maryland Campus located at 51 Mannakee Street in Rockville, Maryland. Tidewater performed the IEQ and mold survey on January 31, 2020 between the hours of 7:00 AM and 1:00 PM.

The CB Building is currently shut down due to on-going water intrusion problems that have affected the building. The testing was conducted on behalf of Montgomery College to document background IEQ comfort parameters, total volatile organic compounds (TVOCs) concentrations, and total airborne mold spore concentrations within select locations of the CB Building. The purpose of the survey was to determine if the test parameters were within established guidelines prior to the relocation of employees from the Physical Education (PE) building to the CB Building. The IEQ and mold assessment survey was performed by Tidewater's Project Manager and Certified Industrial Hygienist, Mr. Skanda Abeyesekere MS, CIH, CSP, CHMM.

## **SCOPE**

The testing was limited to select locations located on the 1<sup>st</sup> and 2<sup>nd</sup> Floors of the CB Building that are anticipated to be occupied by the relocating employees. The scope of work for this IEQ and mold survey included the following:

- Visual inspection for evidence of potential indoor air quality problems (including suspect microbial growth, water damage, chemical use/storage, drain traps, sources of allergens/contaminants etc.) that may contribute to indoor air quality problems;
- Direct-read measurements of indoor air quality parameters including temperature (T), relative humidity (RH), carbon dioxide (CO<sub>2</sub>), carbon monoxide (CO), and total volatile organic compounds (TVOCs) for comparison with guidelines established by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) Standard 62.1–2016, Ventilation for Acceptable Indoor Air Quality, and The United States Environmental Protection Agency (US EPA) National Ambient Air Quality Standards (NAAQS); and
- Spore trap air sampling to characterize for total airborne mold spores.

**SAMPLING METHODOLOGY****Comfort Parameter Air Testing**

During the assessment, Tidewater obtained temperature (T), relative humidity (RH), carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO) measurements within select locations of the CB Building using a Metrosonics Indoor Air Quality instrument (Model Number AQ-5000, Serial Number 2319, Calibration Date: February 25, 2019.) Measurements were taken after allowing the instrument to become acclimated to the ambient temperature and relative humidity for approximately five (5) minutes. Measurements were taken over a 5-minute time period at each designated location and the average concentration was recorded. Samples were obtained for comparison with guidelines established by the American Society for Heating Refrigeration and Air Conditioning (ASHRAE) Standard 62.1 – 2016, Ventilation for Acceptable Indoor Air Quality.

A background sample was also obtained outside of the building for comparison to the interior readings.

**Total Volatile Organic Compounds (TVOCs)**

Tidewater collected direct-read measurements for TVOCs from select locations of the CB Building to characterize concentrations of airborne Total Volatile Organic Compounds. The measurements for TVOCs were obtained using a Mini-RAE 2000 Hand Held VOC meter (Model MINIRAE 2000, Serial Number 110-010833.) Measurements were taken after allowing the device to become acclimated to the ambient temperature and relative humidity for five (5) minutes. Measurements were taken over a 5-minute time period at each designated location and the average concentration was recorded.

A background measurement was also obtained outside of the building for comparison to the interior readings.

**Spore Trap Bioaerosol Sampling (Total Spore Analysis)**

Tidewater collected spore trap air samples from select locations of the CB Building to characterize potential airborne total fungal spores. The samples were collected from the same locations where the comfort parameters were recorded. Tidewater obtained the spore trap samples using Allergenco-D cassettes affixed to a Buck BioAire™ Bioaerosol Sampling Pump (Pump Model Number B520 and Serial Number B152473) calibrated to a flow rate of 15.0 Liters per minute. Each sample was run for a period of five (5) minutes at each sample location to collect a total sample volume of 75.0 liters of air. Tidewater also collected a background sample outside of the building for comparison to the interior spore concentrations.

Once collected, the samples were transported to EMSL Analytical Laboratory (EMSL) located in Beltsville, Maryland for analysis. The samples were transported following rigorous chain-of-custody guidelines to ensure proper handling and delivery of the samples. EMSL is accredited in the American Industrial Hygiene Association (AIHA) Environmental Microbiology Laboratory Accreditation Program (EMLAP) and is a successful participant in AIHA's Environmental Microbiology Proficiency Analytical Testing (EMPAT) program (Laboratory Number 102891.) The samples were analyzed via light microscopy at the standardized magnification of 600X. This technique does not allow for the differentiation between *Aspergillus* and *Penicillium* spores because they are morphologically identical. Additionally, the technique does not allow for cultivation, or the identification of spores to the species level, except in a few cases.

**FIELD INSPECTION****Visual Observations****Counseling & Advising (CB) Building**

The following offices were inspected during the visual inspection of the Counseling and Advising (CB) Building: Rooms 105, 109, 116H, 116A, 119, 122D, 122A located on the 1<sup>st</sup> Floor and Rooms 204, 218, and 215 located on the 2<sup>nd</sup> Floor. Tidewater's assessment included a visual inspection of these rooms for evidence of indoor air quality problems (including suspect mold growth, water damage, chemical use/storage, drain traps, sources of allergens/contaminants) that may contribute to indoor air quality problems.

Tidewater did not observe any evidence of past water intrusion on accessible floors or walls in the majority of the rooms inspected on the 1<sup>st</sup> Floor. However, water stained ceiling tiles were observed in Room 109 and Room 116-A. Additionally, missing ceiling tiles were observed in Room 112 and Room 116-H. No suspect mold formations were observed in any of the areas inspected. The office areas appeared to be relatively clean; however, particulate matter/accumulated dust was observed on the supply air diffusers in Room 105 and Room 109. Tidewater did not detect any significant odors emanating from any of the areas inspected on the 1<sup>st</sup> Floor of the CB Building, although the overall air appeared to be stagnant with poor ventilation.

The areas inspected on the 2<sup>nd</sup> Floor, Rooms 204 and 218, and the lobby area of Suite 215 appeared to be cluttered. Furthermore, the carpeting in Room 204, Room 218 and Suite 215 were stained. Access debris and settled dust was observed on the carpet in these areas. Water stained ceiling tiles and missing ceiling tiles were observed in multiple locations in Suite 215. No suspect mold formations were observed in any of the areas inspected.

The Counseling and Advising (CB) Building is equipped with constant volume heating ventilation and air conditioning systems. There is no means of humidity control in the CB building. The humidity is lowered by lowering the temperature of the thermostats of the Heating Ventilation and Air Conditioning (HVAC) systems. The CB Building is currently unoccupied. The employees in the CB Building have been temporarily relocated to other buildings on the campus due to on-going water intrusion problems. The HVAC system is not in operation at its optimum capacity due to the building being vacant. Maintenance of the HVAC systems in the CB Building is reportedly performed approximately every three (3) months on a preventive maintenance schedule.

**SAMPLING RESULTS**

The indoor air quality parameters, total volatile organic compounds, and microbial spore traps results are summarized in this section. The corresponding laboratory analytical reports and chain of custody forms are included as appendices.

**Comfort Parameters**

According to the American Society for Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE) guidelines Standard 62.1 – 2016, the temperature range in summer months should be maintained between 73.0° F and 79.0° F for maximum occupant comfort. The ASHRAE guideline for temperature for winter months is between 68.0° F and 74.5° F. Temperature levels within the assessed areas of the CB Building ranged between 64.7° F and 68.7° F, compared with a background (outdoors) average temperature of 58.4° F. The interior temperature



readings in a number of locations assessed in the CB Building were below the ASHRAE recommended temperature guideline of 68.0° F and 74.5° F for winter months.

Per the same guidelines, a maximum recommended relative humidity level of 65.0% is recommended to reduce the likelihood of condensation on cold surfaces and potential microbial growth. Measurements of relative humidity levels within the assessed areas of the CB Building ranged between 20.5% and 25.0%, compared with a background (outdoors) relative humidity level of 28.6%. All interior readings were below the ASHRAE Standard 62.1 – 2016 recommended guideline of 65.0%.

ASHRAE Standard 62.1 – 2016 recommends that indoor CO<sub>2</sub> levels not exceed 700 ppm above the outdoor (background) CO<sub>2</sub> level. The CO<sub>2</sub> readings in the assessed areas of the CB Building ranged between 456 ppm and 578 ppm, compared with an outdoor concentration of 520 ppm. The interior CO<sub>2</sub> readings in all areas assessed in the CB Building did not exceed 700 ppm above the outdoor (background) CO<sub>2</sub> levels and therefore were within ASHRAE Standard 62.1 – 2016 for CO<sub>2</sub>.

The CO levels were taken for comparison to the primary standard established by the Environmental Protection Agency (EPA.) Based on the National Ambient Air Quality Standard (NAAQS) set by the EPA, the maximum CO concentration for occupational settings is 9.0 ppm. The CO levels within all areas assessed in the CB building were below 9.0 ppm and therefore were within the EPA NAAQ standard.

The results for the comfort parameter monitoring are provided in Table 1, below. A floor plan including sampling locations is included in **Appendix C**. The calibration certificate for the AQ-5000 Indoor Air Quality instrument is included in **Appendix D**.

TABLE 1: Comfort Parameters				
Sample Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)
<b>Counseling &amp; Advising Building January 31, 2020</b>				
Office 105	67.0	23.0	468	0.0
Office 109	67.2	23.0	470	0.0
Office 116-H	68.0	22.9	476	0.0
Office 116-A	68.5	22.4	476	0.0
Office 119	68.7	22.0	519	0.0
Office 122-D	68.1	23.8	507	0.0
Office 122-A	66.9	24.2	578	0.0
Office 204	64.7	25.0	523	0.0
Office 218	67.6	20.8	456	0.0
Office 215 - Central Areas	68.5	20.5	462	0.0
<b>Background (Outdoors)</b>	58.4	28.6	520	0.0

**Red = Below** American Society for Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE) guidelines Standard 62.1 – 2016 for winter months.



**Total Volatile Organic Compounds (TVOCs) - MiniRAE**

There are no OSHA published guidelines for TVOCs. However, in general, the indoor air quality TVOC threshold for typical indoor occupied environments should not exceed 1,000 ppb (1.0 ppm) isobutylene units. The TVOC concentrations recorded in the building were all well below the recommend threshold level.

The results of the direct read TVOC monitoring are provided in Table 2, below. A floor plan including sampling locations is included in **Appendix C**. The calibration certificate for the Mini-RAE 2000 Hand Held VOC meter is included in **Appendix D**.

<b>TABLE 2: TVOC Measurements</b>		
<b>Location</b>	<b>Average Result (ppm)</b>	<b>Threshold of 1000 ppb (1.0 ppm) Exceeded?</b>
<b>Counseling &amp; Advising Building January 31, 2020</b>		
Office 105	0.0	No
Office 109	0.0	No
Office 116-H	0.0	No
Office 116-A	0.0	No
Office 119	0.0	No
Office 122-D	0.0	No
Office 122-A	0.0	No
Office 204	0.0	No
Office 218	0.0	No
Office 215 - Central Areas	0.0	No
<b>Background (Outdoors)</b>	0.0	No

**Spore Trap Bioaerosol Sampling**

There are no universally accepted federal or State of Maryland standards for acceptable airborne concentrations of bioaerosols in an indoor occupational environment. In general, airborne concentrations indoors should be less than that found in the outdoor air, with similar species composition. Indoor spore counts significantly greater than outdoor concentrations, or the presence of large concentrations of different spore types indoors which are not found outdoors, may indicate potential microbial contamination in the sampled areas. Elevated counts are not necessarily an indication of active microbial growth.

The total mold spore concentrations in the samples collected inside the CB building ranged between None Detected and 300 Counts/m<sup>3</sup>. The background mold spore concentration was 240 Counts/m<sup>3</sup>. It should be noted that precipitation during this testing likely resulted in lower ambient spore concentrations.

The interior total mold spore concentration in Office 122-D marginally exceeded the total mold spore concentration of the background sample. Additionally, the *Aspergillus/Penicillium* concentration in Office 122-D exceeded the concentration detected in the background/outside



sample (None Detected.) Although the *Aspergillus/Penicillium* concentration in Office 122-D was slightly higher than the outside concentration, it was consistent with the total spore concentration outside and is unlikely to be an indication of a fungal reservoir inside the building. Tidewater did not observe any evidence of suspect mold formations in Office 122-D at the time of this testing.

The results for the spore trap sampling are provided in Table 3, below. The laboratory analytical reports and chain of custody forms are included in **Appendix B**. A floor plan including sampling locations is included in **Appendix C**.

Table 3: Spore Trap Bioaerosol Results				
Sample #	Sample Location (Room / Cubicle)	Sample Volume (L)	<i>Aspergillus/ Penicilium</i> (Counts/m <sup>3</sup> )	Total Fungi Concentration (Counts/m <sup>3</sup> )
<b>Counseling &amp; Advising Building January 31, 2020</b>				
CB-1	Office 105	75.0	40	170
CB-2	Office 109	75.0	None Detected	90
CB-3	Office 116-H	75.0	None Detected	40
CB-4	Office 116-A	75.0	None Detected	40
CB-5	Office 119	75.0	90	220
CB-6	Office 122-D	75.0	<b>300</b>	<b>300</b>
CB-7	Office 122-A	75.0	None Detected	None Detected
CB-8	Office 204	75.0	None Detected	None Detected
CB-9	Office 218	75.0	None Detected	None Detected
CB-10	Office 215 - Central Areas	75.0	None Detected	None Detected
BG-1	Background	75.0	None Detected	240

**Red** = Total mold spore concentration is above background concentration.



## **CONCLUSIONS**

- The following conditions of concern were noted during the visual inspection: water-stained ceiling tiles in Room 109, Room 116-A and Room 215; missing ceiling tiles in Room 116-H and Suite 215; excessive particulate matter/accumulated dust on supply air diffusers in Room 105 and Room 109.; and stained/dirty carpet in Room 204, Room 218, and the lobby area of Suite 215.
- The interior temperature readings in a number of locations assessed in the CB Building were below the temperature guideline of 68.0°F and 74.5°F recommended in ASHRAE Standard 62.1 – 2016 for winter months.
- Relative humidity, CO<sub>2</sub>, CO, and TVOC readings recorded in the building during this survey were within industry standards and guidelines.
- A review of the spore trap bioaerosol sampling results did not indicate the presence of a fungal reservoir inside the building. Tidewater did not observe any evidence of suspect mold formations on readily accessible surfaces in the surveyed building areas.

## **RECOMMENDATIONS**

- Adjust the thermostats of the HVAC systems supplying the CB building in order to maintain a temperature level between 68.0°F and 74.5°F recommended in ASHRAE Standard 62.1 – 2016 for winter months.
- Investigate above drop ceiling in Room 109, Room 116-A and Suite 215 for ongoing condensation leaks or other potential water sources within the CB Building. If any on-going water leaks are detected, repair them immediately. If surface mold contamination is observed, appropriate steps should be taken to remediate and sanitize the affected areas.
- Remove all water stained/ water damaged ceiling tiles in the above mentioned areas. Ensure that the perimeter of the ceiling grids in each area is cleaned with a 10% bleach solution prior to installing new ceiling tiles. Replace all missing ceiling tiles in these areas.
- Ensure that all reinstallation and cleanup activities are conducted after hours when the rooms are unoccupied to minimize exposure to occupants.
- Replace missing ceiling tiles in Room 116-H and Suite 215.
- Cleaned/disinfect the return air grills in Room 109 and Room 105 to remove visible particulate matter and accumulated dust.
- Ensure the Heating Ventilation and Air Conditioning (HVAC) System supplying air to the CB Building is properly balanced per design requirements and current occupancy/use in order to ensure adequate ventilation throughout the rooms.
- Ensure that the ventilation systems are turned on in all rooms and are operating at all times when the rooms are occupied to provide sufficient air flow and ventilation.
- Tidewater recommends vacuum cleaning (stream cleaning) all carpeting on the 1<sup>st</sup> and 2<sup>nd</sup> Floors and wiping down all horizontal surfaces with disinfectant cleaning solution to remove settled dust and debris prior to relocating employees to the CB Building



- All complaints related to allergies, odors, and poor indoor quality should be closely monitored and recorded after employees are relocated.

**QUALIFICATIONS**

Tidewater has endeavored to investigate existing conditions associated with select areas of the Counseling & Advising (CB) Building located on the Montgomery College Rockville Campus at 51 Mannakee Street in Rockville, Maryland as they pertain to indoor air quality. Regardless of the thoroughness of our investigation, it is possible that some contributing factor may have been overlooked or that circumstances have changed without our knowledge. Our results are based on the observations made on the day of our investigation and information provided by our Client. Actual conditions vary from day to day throughout the year.

Tidewater appreciates the opportunity to provide consulting services for Montgomery College on this matter. Please contact us should any questions arise concerning this report or if we may be of further assistance.

Sincerely,  
Tidewater, Inc.

A handwritten signature in black ink, appearing to read "Skanda Abeysekere".

Skanda Abeysekere, MS, CIH, CSP, CHMM  
Project Manager/ Certified Industrial Hygienist


SA/JG

Appendices:      Appendix A – Photograph Log  
                         Appendix B – Laboratory Reports and Chain of Custody Forms  
                         Appendix C – Building Floorplan with Sample Locations  
                         Appendix D – Instrument Calibration Reports





**APPENDIX A**  
**PHOTOGRAPH LOG**



**Photo No. 1:** CB Building, Room 105 - particulate matter and accumulated dust on air supply diffuser.



**Photo No. 2:** CB Building, Room 109 – particulate matter and accumulated dust on air supply diffuser.



**Photo No. 3:** CB Building, Room 109 – Ceiling tile with minor water stains.



**Photo No. 4:** CB Building, Room 122 - Missing Ceiling Tile.




**Photo No. 5:** CB Building, Room 116-H - Missing Ceiling Tile.



**Photo No. 6:** CB Building, Room 122-D.



**Photo No. 7:** CB Building, Room 204 – Heavily-stained carpeting.



**Photo No. 8:** CB Building, Room 204 – Debris on Carpeting.



**Photo No. 9:** CB Building, Room 218 – Heavily-stained carpeting.



**Photo No. 10:** CB Building, Suite 215 (Center) – Heavily-stained carpeting.



**Photo No. 11:** CB Building, Room 215 – Water-stained / missing ceiling tiles.



**Photo No. 12:** CB Building, Room 215 – Water-stained ceiling tiles.



**APPENDIX B**

**LABORATORY REPORTS AND CHAIN OF CUSTODY FORMS**





# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com/beltsvillelab@emsl.com>

EMSL Order: 192001188

Customer ID: TIDE50

Customer PO:

Project ID:

**Attn:** Skanda Abeyeskere

Tidewater, Inc.

6625 Selnick Drive

Suite A

Elkridge, MD 21075

**Project:** CB-Building (Air Samples) MC-Rockville

**Phone:** (443) 983-0362

**Fax:** (410) 997-8713

**Collected:** 01/31/2020

**Received:** 01/31/2020

**Analyzed:** 01/31/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	192001188-0001 CB-1 75 Room 105			192001188-0002 CB-2 75 Room 109			192001188-0003 CB-3 75 Room 116H		
	Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>
Alternaria (Ulocladium)	-	-	-	-	-	-	1	40	100
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	1	40	23.5	-	-	-	-	-	-
Basidiospores	2	90	52.9	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	1	40	23.5	-	-	-	-	-	-
Cladosporium	-	-	-	1	40	44.4	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	1*	10*	11.1	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	44.4	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>4</b>	<b>170</b>	<b>100</b>	<b>3</b>	<b>90</b>	<b>100</b>	<b>1</b>	<b>40</b>	<b>100</b>
Hypthal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	3	-	-	3	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager  
or other approved signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 01/31/2020 16:18:46

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

EMSL Order: 192001188

Customer ID: TIDE50

Customer PO:

Project ID:

**Attn:** Skanda Abeyeskere

Tidewater, Inc.

6625 Selnick Drive

Suite A

Elkridge, MD 21075

**Project:** CB-Building (Air Samples) MC-Rockville

**Phone:** (443) 983-0362

**Fax:** (410) 997-8713

**Collected:** 01/31/2020

**Received:** 01/31/2020

**Analyzed:** 01/31/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	192001188-0004 CB-4 75 Room 116A			192001188-0005 CB-5 75 Room 119			192001188-0006 CB-6 75 Room 122D			
	Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	2	90	40.9	7	300	100	-
Basidiospores	1	40	100	2	90	40.9	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	18.2	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>1</b>	<b>40</b>	<b>100</b>	<b>5</b>	<b>220</b>	<b>100</b>	<b>7</b>	<b>300</b>	<b>100</b>	<b>-</b>
Hyphal Fragment	-	-	-	1	40	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	1	40	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	3	-	-	4	-	-	2	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	2	-	-	2	-	-	2	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager  
or other approved signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 01/31/2020 16:18:46

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

EMSL Order: 192001188

Customer ID: TIDE50

Customer PO:

Project ID:

**Attn:** Skanda Abeyeskere

Tidewater, Inc.

6625 Selnick Drive

Suite A

Elkridge, MD 21075

**Project:** CB-Building (Air Samples) MC-Rockville

**Phone:** (443) 983-0362

**Fax:** (410) 997-8713

**Collected:** 01/31/2020

**Received:** 01/31/2020

**Analyzed:** 01/31/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	192001188-0007 CB-7 75 Room 122A			192001188-0008 CB-8 75 Room 204			192001188-0009 CB-9 75 Room 218			
	Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	-	<b>None Detect</b>	-	-	<b>None Detect</b>	-	-	<b>None Detect</b>	-	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	1	40	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	3	-	-	4	-	-	3	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	2	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager  
or other approved signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 01/31/2020 16:18:46

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

EMSL Order: 192001188

Customer ID: TIDE50

Customer PO:

Project ID:

**Attn:** Skanda Abeyeskere

Tidewater, Inc.

6625 Selnick Drive

Suite A

Elkridge, MD 21075

**Project:** CB-Building (Air Samples) MC-Rockville

**Phone:** (443) 983-0362

**Fax:** (410) 997-8713

**Collected:** 01/31/2020

**Received:** 01/31/2020

**Analyzed:** 01/31/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	192001188-0010			192001188-0011		
	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
CB-10				BG		
Room 215G				Background		
<b>Spore Types</b>						
Alternaria (Ulocladium)	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-
Basidiospores	-	-	-	5	200	83.3
Bipolaris++	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-
Myxomycetes++	-	-	-	3*	40*	16.7
Pithomyces++	-	-	-	-	-	-
Rust	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-
<b>Total Fungi</b>	-	<b>None Detect</b>	-	<b>8</b>	<b>240</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-
Pollen	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-
Background (1-5)	-	1	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager  
or other approved signatory

No discernable field blank was submitted with this group of samples.

Samples received in good condition unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 01/31/2020 16:18:46

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)

## Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

192001188

PHONE:  
FAX:

Company: Tidewater Inc		EMSL-Bill to: <input type="checkbox"/> Different <input type="checkbox"/> Same <small>If Bill to is Different note instructions in Comments**</small>	
Street: 6625 Selnick Drive, Suite A		<i>Third Party Billing requires written authorization from third party</i>	
City: Elkridge	State/Province: MD	Zip/Postal Code: 21075	Country: U.S.
Report To (Name): Skanda Abeyesekere		Telephone #: 443-983-0362	
Email Address: skanda@tideh2o.net		Fax #: 410-579-1685	Purchase Order:
Project Name/Number: <del>CB</del> -Building (Air-Samples)MC-Rockville		Please Provide Results: <input type="checkbox"/> FAX <input type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: Maryland		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	

**Turnaround Time (TAT) Options\* - Please Check**

3 Hour   
  6 Hour   
  24 Hour   
  48 Hour   
  72 Hour   
  96 Hour   
  1 Week   
  2 Week

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

**Non Culturable Air Samples (Spore Traps) – Test Codes**

• M001 Air-O-Cell	• M173 Allegro M2	• M004 Allergenco	• M032 Allergenco-D	• M172 Versa Trap
• M049 BioSIS	• M003 Burkard	• M043 Cyclex	• M002 Cyclex-d	
• M030 Micro 5	• M174 MoldSnap	• M176 Relle Smart	• M130 Via-Cell	

**Other Microbiology Test Codes**

• M041 Fungal Direct Examination • M005 Viable Fungi ID and Count • M006 Viable Fungi ID and Count (Speciation) • M007 Culturable Fungi • M008 Culturable Fungi (Speciation) • M009 Gram Stain Culturable Bacteria • M010 Bacterial Count and ID – 3 Most Prominent • M011 Bacterial Count and ID – 5 Most Prominent • M013 Sewage Contamination in Buildings	• M014 Endotoxin Analysis • M015 Heterotrophic Plate Count • M180 Real Time Q-PCR-ERMI 36 Panel • M018 Total Coliform (Membrane Filtration) • M020 Fecal Streptococcus (Membrane Filtration) • M210-215 Legionella Detection • M026 Recreational Water Screen • M027 Mycotoxin Analysis	• M029 Enterococci • M019 Fecal Coliform • M133 MRSA Analysis • M028 <i>Cryptococcus neoformans</i> Detection • M120 <i>Histoplasma capsulatum</i> Detection • M033-39 Allergen Testing • M044 Group Allergen (Cat, Dog, Cockroach, Dustmites) • Other See Analytical Price Guide
---	--	--

**Preservation Method (Water):**

Name of Sampler: <i>Skanda Abeyesekere</i>	Signature of Sampler: <i>SKANDA ABEYESEKERE</i>
--	---

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example: A1	Kitchen	Air	M001	75L	11/12 4:00 PM
CB-1	Room 105	Air	M001	75L	01/31/2020
CB-2	Room 109	↓	↓	↓	↓
CB-3	Room 116A				
CB-4	Room 116A				
CB-5	Room 119				
CB-6	Room 122D				
CB-7	Room 122A				
CB-8	Room 204				
CB-9	Room 218				

Client Sample # (s): 11      Total # of Samples: "

Relinquished (Client): <i>Skanda Abeyesekere</i>	Date: 01/31/20	Time: 8:30pm
Received (Client): <i>Houtman</i> Walk In	Date: 01/31/20	Time: 1:11PM

Comments: skanda@tideh2o.net / okahawita@yahoo.com / (shamila.pradhan@montgomerycollege.edu) / michael.rocke@montgomerycollege.edu (mai.toyofuku@montgomerycollege.edu)

### Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

192001188

PHONE:  
FAX:

Company: Tidewater Inc		EMSL-Bill to: <input type="checkbox"/> Different <input type="checkbox"/> Same If Bill to is Different note instructions in Comments**	
Street: 6625 Selnick Drive, Suite A		Third Party Billing requires written authorization from third party	
City: Elkridge	State/Province: MD	Zip/Postal Code: 21075	Country: U.S.
Report To (Name): Skanda Abeyesekere		Telephone #: 443-983-0362	
Email Address: skanda@tideh2o.net		Fax #: 410-579-1685	Purchase Order:
Project Name/Number: <del>E</del> -Building (Air-Samples)MC-Rockville		Please Provide Results: <input type="checkbox"/> FAX <input type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: Maryland		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	

Turnaround Time (TAT) Options\* - Please Check

3 Hour  6 Hour  24 Hour  48 Hour  72 Hour  96 Hour  1 Week  2 Week

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

Non Culturable Air Samples (Spore Traps) - Test Codes

- M001 Air-O-Cell
- M049 BioSIS
- M030 Micro 5
- M173 Allegro M2
- M003 Burkard
- M174 MoldSnap
- M004 Allergenco
- M043 Cyclex
- M176 Relle Smart
- M032 Allergenco-D
- M002 Cyclex-d
- M130 Via-Cell
- M172 Versa Trap

Other Microbiology Test Codes

- M041 Fungal Direct Examination
- M005 Viable Fungi ID and Count
- M006 Viable Fungi ID and Count (Speciation)
- M007 Culturable Fungi
- M008 Culturable Fungi (Speciation)
- M009 Gram Stain Culturable Bacteria
- M010 Bacterial Count and ID - 3 Most Prominent
- M011 Bacterial Count and ID - 5 Most Prominent
- M013 Sewage Contamination in Buildings
- M014 Endotoxin Analysis
- M015 Heterotrophic Plate Count
- M180 Real Time Q-PCR-ERMI 36 Panel
- M018 Total Coliform (Membrane Filtration)
- M020 Fecal Streptococcus (Membrane Filtration)
- M210-215 Legionella Detection
- M026 Recreational Water Screen
- M027 Mycotoxin Analysis
- M029 Enterococci
- M019 Fecal Coliform
- M133 MRSA Analysis
- M028 Cryptococcus neoformans Detection
- M120 Histoplasma capsulatum Detection
- M033-39 Allergen Testing (Cat, Dog, Cockroach, Dustmites)
- M044 Group Allergen (Cat, Dog, Cockroach, Dustmites)
- Other See Analytical Price Guide

Preservation Method (Water):

Name of Sampler:	Signature of Sampler:
------------------	-----------------------

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example: A1	Kitchen	Air	M001	75L	1/1/12 4:00 PM
CB-10	Room 215G	Air	M001	70	01/31/2020
B6G	Background	Air	M001	70	

Client Sample # (s):	-	Total # of Samples:
----------------------	---	---------------------

Relinquished (Client):	Date:	Time:
------------------------	-------	-------

Received (Client):	Date:	Time:
--------------------	-------	-------

Comments:  
skanda@tideh2o.net / okahawita@yahoo.com / (sharmila.pradhan@montgomerycollege.edu) / michael.rocke@montgomerycollege.edu  
(mai.toyofuku@montgomerycollege.edu)



**APPENDIX C**

**BUILDING FLOOR PLAN WITH SAMPLE LOCATIONS**



**Attachment C**  
**CB Building**  
**First Floor Sampling Locations**


Scale: N/A

Project #: 5089-017  
 Date: January 31, 2020

General Notes

▲ = Sample Location





General Notes

Scale: N/A

Project #: 5089-017  
Date: January 31, 2020

▲ = Sample Location

**Attachment C**  
**CB Building**  
**Second Floor Sampling Locations**





**APPENDIX D**  
**INSTRUMENT CALIBRATION REPORTS**

# INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

**Tidewater, Inc.**

**Instrument ID** 2319  
**Description** Metrosonics AQ-5000  
**Calibrated** 2/25/2019

**Manufacturer** Metrosonics  
**Model Number** AQ-5000  
**Serial Number** 2319  
**Location** New Jersey  
**Temp** 71

**Classification**  
**Status** Pass  
**Frequency** Yearly EOM  
**Department**  
**Humidity** 21

### Calibration Specifications

<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
<b>Group # 1</b> <b>Group Name</b> Carbon Dioxide <b>Stated Accy</b> Pct of Reading				<b>Range Acc %</b> 0.0000 <b>Reading Acc %</b> 3.0000 <b>Plus/Minus</b> 0.00			
0.00 / 0.00	PPM	0.00	PPM	20.00	0.00	0.00%	Pass
5000.00 / 5000.00	PPM	5000.00	PPM	5,080.00	4,960.00	-0.80%	Pass
<b>Group # 2</b> <b>Group Name</b> Relative Humidity <b>Stated Accy</b> Pct of Reading				<b>Range Acc %</b> 0.0000 <b>Reading Acc %</b> 3.0000 <b>Plus/Minus</b> 0.00			
30.00 / 30.50	%	30.50	%	30.20	30.20	-0.98%	Pass
<b>Group # 3</b> <b>Group Name</b> Temperature <b>Stated Accy</b> Plus / Minus				<b>Range Acc %</b> 0.0000 <b>Reading Acc %</b> 0.0000 <b>Plus/Minus</b> 0.90			
70.00 / 66.00	°F	66.00	°F	66.20	66.20	0.30%	Pass
<b>Group # 4</b> <b>Group Name</b> Carbon Monoxide <b>Stated Accy</b> Pct of Reading				<b>Range Acc %</b> 0.0000 <b>Reading Acc %</b> 3.0000 <b>Plus/Minus</b> 0.00			
0.00 / 0.00	PPM	0.00	PPM	0.00	0.00	0.00%	Pass
200.00 / 200.00	PPM	200.00	PPM	170.00	201.00	0.50%	Pass

# INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

**Tidewater, Inc.**

**Instrument ID** 2319  
**Description** Metrosonics AQ-5000  
**Calibrated** 2/25/2019

## Test Instruments Used During the Calibration

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Serial Number</u>	<u>(As Of Cal Entry Date)</u>	
				<u>Last Cal Date</u>	<u>Next Cal Date</u>
CO 200PPM 34LS-50-200	CO 200ppm GAP-50-200-3	Spec Air	34LS-50-200	6/1/2015	6/16/2019
CO2 5000PPM CAQ-34-5000-5	Carbon Dioxide 5000 PPM LOT # LTB192-MD-CM	Liquid Technology	CAQ-35-5000-5	2/1/2016	2/22/2020
MICHELL DM-509-TX-01	Relative Humidity Meter	Michell	273296	9/17/2018	9/17/2019
NITROGEN	Nitrogen 99.999%	Liquid Technology	7727-37-9	6/1/2016	6/1/2019
ZERO_AIR_105 L-1	Zero Grade Air THC <1.0 PPM	Liquid Technology	KAP-A-10	10/1/2015	10/20/2019

## Notes about this calibration

**Calibration Result** Calibration Successful  
**Who Calibrated** David Galego

**Advanced Labs, Inc. hereby certifies that this instrument is calibrated and functions to meet the manufacture's specifications using NIST traceable standards, or is derived from accepted values of physical constants.**

# Certificate of Conformance

Buck BioAire™

Buck BioSlide™

Serial number: B152473 Date Issued: 3-29-19

## **Flow Calibration**

The instrument listed above is in conformance with factory specifications and the flow is set to nominal using a BUCK Calibrator which is N.I.S.T. traceable to A. P. Buck, Inc. Calibration Procedure APB-1, Ver. 6.2.

**QA APPROVAL BY:** Thomas J. Lawrence


Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602 • Fax: 407-851-8910

**BUCK**

A.P. BUCK, INC.

COCR-004 REV-01 3/3/2006



# INSTRUMENT CALIBRATION REPORT

Pine Environmental Services, LLC.

## Tidewater MD

**Instrument ID** 110-010833  
**Description** MINIRAE 2000  
**Calibrated** 4/9/2019

**Manufacturer** Rae Systems  
**Model Number** MINIRAE 2000  
**Serial Number** 110-010833  
**Location** Maryland  
**Department** CATHY MOORE

**Frequency** 6 Months  
**Status** Pass  
**Temp** 24  
**Humidity** 39

### Calibration Specifications

**Group #** 1  
**Group Name** ISOBUTYLENE  
**Stated Accy** Pct of Reading

**Range Acc %** 0.0000  
**Reading Acc %** 3.0000  
**Plus/Minus** 0.00

<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
100.00 / 100.00	ppm	100.00	ppm	92.80	101.00	1.00%	Pass

### Test Instruments Used During the Calibration

(As Of Cal Entry Date)

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>Last Cal Date</u>	<u>Next Cal Date / Expiration Date</u>
MD ISO 100PPM FBI-248-100-12	MD ISO 100PPM	Pine Environmental Services, Inc.	FBI-248-100-12	34LS-248-100	5/23/2022	
MD ZERO AIR FBI-1-25	ZERO AIR Oxygen 20.9%VOL, Nitrogen Balance	Pine Environmental Services, Inc.	31844	FBI-1-25		

### Notes about this calibration

**Calibration Result** Calibration Successful  
**Who Calibrated** Ryan Armstrong

Pine Environmental Services, LLC. hereby certifies that this instrument is calibrated and functions to meet the manufacturer's specifications using NIST traceable standards, or is derived from accepted values of physical constants.